



MPA External detector alarm display according to DIN14623



The external detector alarm display is required if the detector is not directly visible or has been mounted in false ceilings or false floors. The external detector alarm display should be mounted in corridors or access pathways to the corresponding building sections or rooms.

The transparent red alarm display conforms to DIN 14623.

Certifications and Approvals

VdS approval number: **G 294 052**

ATEX certification: PTB 01 ATEX 2163X

Technical Specifications

MPA External detector alarm display

Operating voltage	9 V DC . . . 30 V DC
Current consumption for display	
• T.2	Approx. 2 mA
• T.3	Limited to approx. 13 mA
• T.4	Limited to 20 mA maximum
Display medium	1 LED via a light guide
Permissible wire gauge	0.6 mm ... 0.8 mm
Dimensions	85 x 85 x 50 mm
Weight	65 g

Ordering Information

MPA External detector alarm display according to DIN14623 MPA